



SECTION A-A

NOTES:

1. The precise location of F.H. relative to the lot line or the B.C. offset may be shifted up to 5' to avoid conflict with street lights, mail boxes or driveway approaches (provide 4' clearance from these improvements).
2. Location of F.H. must be approved by Ventura County Fire Protection District.
3. See City of Thousand Oaks Water Design Standards for additional location requirements.
4. No shrubs, bushes or improvements exceeding 6" in height within this area.
5. Circular or rectangular configuration for concrete pad.
6. Easement to City of Thousand Oaks or water purveyor is required.

				CITY OF THOUSAND OAKS PUBLIC WORKS DEPARTMENT	
5	Revised F.H. Offset Dimensions & Notes	10-22-08	MAP		
CHG	DESCRIPTION	DATE	INITIAL	STANDARD LOCATION OF FIRE HYDRANT IN MONOLITHIC SIDEWALK AREAS	
APPROVED <i>Jay Krueger</i> 10/23/08 CITY ENGINEER DATE					
				PLATE NO. <b>8-7</b>	