



NOTE:

1. VALVE OPERATING NUTS SHALL NOT BE GREATER THAN 4.5' BELOW THE FINISHED SURFACE. EXTENSION STEMS WITH ROCK SHIELDS SHALL BE PROVIDED WHERE DEPTHS EXCEED 4.5'. TOP OF EXTENSION SHALL BE A MINIMUM OF 1' AND A MAXIMUM OF 3' BELOW THE FINISHED SURFACE. EXTENSION STEM SHALL NOT EXCEED 5' IN LENGTH.
2. FOR VALVES LOCATED IN CONCRETE DRIVES, SIDEWALKS, OR LANDSCAPING A CHRISTY G3 VALVE BOX COVER SHALL BE USED.
3. VALVE BOXES SHALL NOT BE LOCATED IN CROSS GUTTERS OR FLOWLINES.

				CITY OF THOUSAND OAKS PUBLIC WORKS DEPARTMENT	
CHG	DESCRIPTION	DATE	INITIAL	VALVE BOX INSTALLATION	
APPROVED <i>Jay Swygier</i> 6.10.09 CITY ENGINEER DATE					