



NOTES:

1. STANDARD DEPTH OF COVER IS 36" MIN. FOR 6" AND 8" DIA. PIPE, AND 42" MIN. FOR 10" AND LARGER DIA. PIPE AND FOR PIPES INSTALLED IN UNPAVED AREAS.
2. BACKFILL MATERIAL WITHIN THE PIPE ZONE AND THE TRENCH ZONE SHALL BE PER SECTION 3-11 OF DESIGN STANDARDS.
3. PLACEMENT AND COMPACTION OF PIPE ZONE AND TRENCH ZONE MATERIAL SHALL BE PER SECTION 7-15 OF DESIGN STANDARDS.
4. RESURFACING AND RESTORATION OF TRENCH SHALL BE PER SECTION 7-16 OF DESIGN STANDARDS.

				CITY OF THOUSAND OAKS	
				PUBLIC WORKS DEPARTMENT	
CHG	DESCRIPTION	DATE	INITIAL	TRENCH DETAIL	
APPROVED <i>Jay L. Surgeni</i>					
			6.10.09		
			DATE		
CITY ENGINEER					