



**NOTES:**

1. MINIMUM COVER FOR 8" AND SMALLER DIA. PIPES IS 36". MINIMUM COVER FOR 10" AND LARGER DIA. PIPES IS 42". PRIOR TO DEVIATION OF THIS REQUIREMENT AND THE USE OF THIS PLATE, SPECIAL PERMISSION FROM THE CITY OF THOUSAND OAKS IS REQUIRED.
2. ENCASEMENT SHALL EXTEND A MINIMUM 5' BEYOND THE LIMIT OF LESS-THAN-MINIMUM COVER. A FLEXIBLE JOINT SHALL BE INSTALLED WITHIN 24" FROM THE END OF THE ENCASEMENT.
3. BACKFILL AND COMPACTION WITHIN THE TRENCH ZONE, AND RESURFACING AND RESTORATION OF THE TRENCH SHALL BE PER PLATE 32-1.

				<b>CITY OF THOUSAND OAKS</b>	
				PUBLIC WORKS DEPARTMENT	
CHG	DESCRIPTION	DATE	INITIAL	<b>PIPE ENCASEMENT FOR LESS-THAN-MINIMUM COVER</b>	
APPROVED	<i>Jay S. Ferguson</i> CITY ENGINEER	6.10.09 DATE			