



NOTES:

1. MINIMUM SEPARATION BETWEEN CROSSING FACILITIES IS 12". PRIOR TO DEVIATION OF THIS REQUIREMENT AND THE USE OF THIS PLATE, SPECIAL PERMISSION FROM THE CITY OF THOUSAND OAKS AND THE OWNER OF THE EXISTING PIPELINE IS REQUIRED.
2. WHEN A WATERLINE CROSSES A WASTEWATER LINE, SEPARATION REQUIREMENTS SHALL BE DETERMINED BY THE CALIFORNIA DEPARTMENT OF PUBLIC HEALTH GUIDELINES.
3. PIPE SECTIONS SHALL BE CENTERED AT THE CROSSING IN ORDER TO MAINTAIN MAXIMUM DISTANCE FROM CROSSING TO THE PIPE JOINTS.

				CITY OF THOUSAND OAKS	
				PUBLIC WORKS DEPARTMENT	
CHG	DESCRIPTION	DATE	INITIAL	WATER MAIN CROSSING UNDER EXISTING PIPELINE	
APPROVED <i>Jay A. Morgan</i> CITY ENGINEER				6.10.09 DATE	32-3