



NOTES:

1. METER SIZE TO BE APPROVED BY VENTURA COUNTY FIRE PROTECTION DISTRICT.
2. INSTALLATION OF SERVICE LINE, METER, AND METER BOX SHALL BE AS SHOWN ON PLATE 36-2.
3. DEVELOPER SHALL INSTALL A FORD LTBA 443-444W-AWT-Q-NL (NO LEAD) OR MUELLER B25251N (NO LEAD) SHUT-OFF MANIFOLD OR EQUIVALENT.
4. A FORD BBIM-44 METER COUPLING BUSHING, OR EQUIVALENT, MAY BE USED TO CONNECT THE CUSTOMER HAND VALVE TO THE SHUT-OFF MANIFOLD.

CHG	DESCRIPTION	DATE	INITIAL
1	ADD BOX / VALVE SPECS	2/4/2013	<i>MLT</i>

CITY OF THOUSAND OAKS
PUBLIC WORKS DEPARTMENT

APPROVED

[Signature]
CITY ENGINEER

2-5-13
DATE

**RESIDENTIAL DUAL FIRE
AND DOMESTIC SERVICE**

PLATE NO.
36-3