



NOTES:

1. BUMPOUT MAY BE USED FOR A FIRE HYDRANT OR AN AIR RELEASE AND VACUUM VALVE.
2. FIRE HYDRANT OUTLETS FACE TOWARD THE STREET.
3. PROTRUDING EDGE OF FIRE HYDRANT OUTLET SHALL BE FLUSH WITH BACK OF SIDEWALK.
4. SLOPE NOT TO EXCEED 2% WITHIN THE EASEMENT AREA. IF SLOPE IS GREATER THAN 2% A RETAINING WALL SHALL BE DESIGNED AND CONSTRUCTED UNDER PERMIT OF THE CITY'S COMMUNITY DEVELOPMENT DEPARTMENT.

				CITY OF THOUSAND OAKS PUBLIC WORKS DEPARTMENT	
CHG	DESCRIPTION	DATE	INITIAL	SIDEWALK BUMPOUT DETAIL FOR FIRE HYDRANT AND AIR/VAC ASSEMBLIES	
APPROVED <i>Jeff Morgan</i> CITY ENGINEER					