



NOTES:

1. FIRE HYDRANT SHALL BE A 6" WET BARREL TYPE. OUTLET CONFIGURATION SHALL BE AS DETERMINED BY THE VENTURA COUNTY FIRE PROTECTION DISTRICT.
2. FIRE HYDRANT OUTLETS SHALL BE POINTED TOWARD STREET, OR MAIN DRIVEWAY, OR AS DIRECTED BY VENTURA COUNTY FIRE PROTECTION DISTRICT.
3. FIRE HYDRANT, SPOOL, AND VALVE CAPS SHALL BE PAINTED IN ACCORDANCE WITH SECTION 3-10.
4. FIRE HYDRANTS LOCATED IN UNDEVELOPED AREAS, OR WHERE STREETS ARE WITHOUT CURBS SHALL BE PROTECTED WITH GUARD POSTS.
5. FOR FIRE HYDRANTS BEING USED AS BLOWOFFS, CONNECT TO MAIN PER PLATE NO. 33-3.
6. A CHECK VALVE SHALL BE INSTALLED FOR APPLICATIONS REQUIRING A BREAK OFF CHECK VALVE.

CHG	DESCRIPTION	DATE	INITIAL
APPROVED	<i>Jay D. Morgan</i> CITY ENGINEER	6.10.09 DATE	

CITY OF THOUSAND OAKS PUBLIC WORKS DEPARTMENT	
FIRE HYDRANT INSTALLATION	PLATE NO. 34-3