



NOTE:

1. FOR GUARD POSTS USED TO PROTECT FIRE HYDRANTS, A CLEAR AREA IS REQUIRED TO PROVIDE CLEARANCE FOR OUTLETS.
2. THE LOCATION OF GUARD POSTS USED TO PROTECT FIRE HYDRANTS SHALL HAVE VENTURA COUNTY FIRE PROTECTION APPROVAL.
3. UNLESS OTHERWISE APPROVED, GUARD POSTS SHALL BE PAINTED THE SAME COLOR AS FIRE HYDRANTS.

				CITY OF THOUSAND OAKS	
				PUBLIC WORKS DEPARTMENT	
CHG	DESCRIPTION	DATE	INITIAL	GUARD POST DETAIL	
APPROVED	<i>Jay D. Morgan</i> CITY ENGINEER	6.10.09 DATE			