



**NOTES:**

1. PRIOR TO INSTALLATION OF THE METER, A SPACER SHALL BE INSTALLED BETWEEN THE ANGLE METER STOP AND THE CUSTOMER HAND VALVE.
2. SERVICE LINE TO BE LAID FLAT OR AT A POSITIVE SLOPE FROM MAIN.

**ZINC ANODE SIZE**

COPPER PIPE LENGTH (FT.)	ANODE SIZE (IN.)	ANODE WEIGHT (LBS.)
0 TO 22	1.4 x 1.4 x 30	15
22 TO 45	2.0 x 2.0 x 30	30
45 TO 70	2.0 x 2.0 x 48	40
70 TO 90	2.0 x 2.0 x 60	60

**CITY OF THOUSAND OAKS  
PUBLIC WORKS DEPARTMENT**

CHG	DESCRIPTION	DATE	INITIAL
APPROVED	<i>[Signature]</i> CITY ENGINEER	6.10.09 DATE	

**2" WATER SERVICE  
WITH 1-1/2" OR 2" METER**

PLATE NO.  
**36-4**