



NOTES:

1. CONNECTION AT MAIN SHALL BE MADE WITH A TAPPING SLEEVE OR A CUT-IN TEE, REDUCER, AND GATE VALVE.
2. THIS PLATE DEPICTS A GENERAL INSTALLATION WHICH MAY OR MAY NOT BE APPROPRIATE IN ALL CASES. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL SUBMIT A PLAN SHOWING THE PROPOSED INSTALLATION. A LIST OF MATERIALS WITH MANUFACTURER'S NAME AND PART OR MODEL NUMBERS SHALL BE PROVIDED TO THE CITY FOR REVIEW AND APPROVAL.

CHG	DESCRIPTION	DATE	INITIAL
APPROVED <i>Jay Spurgeon</i>			6.10.09
CITY ENGINEER			DATE

CITY OF THOUSAND OAKS
PUBLIC WORKS DEPARTMENT

4" WATER SERVICE WITH 3" OR 4" COMPOUND METER	PLATE NO. 36-5
--	--------------------------